

Brief description of the stationary RICE at the facility, including number of engines and the site-rated HP of each engine: There are three spark ignition stationary RICE at the facility. A summary of the engines is provided below:

Pump #3: Existing, non-emergency; 335 hp

Pump #4: Existing, non-emergency; 465 hp

Generator: Existing, emergency; 100 hp

I hereby certify that the information presented herein is correct to the best of my knowledge.

Scott Keep
(Signature)

1-22-13
(Date)

Scott Keep / Senior Vice President, Operations
(Name/title)

(402) 504-7000
(Telephone No.)